

Preliminary Assessment Report

Project 6566181, 9204 11TH AVE NW

Assessment Completed: 11/29/2016

Project Description: DEMO SHED, CONSTRUCT (1) SFR WITH ATTACHED (2) CAR GARAGE.

Primary Applicant: [Julian Weber](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

SDCI Drainage Requirements

Matthew Bateman, (206) 615-1229, Matthew.Bateman@Seattle.gov

SDCI Land Use Requirements

Glenda Warmoth, (206) 733-9695, Glenda.Warmoth@seattle.gov

SDCI Preapplication Site Visit Requirements

Roxanne Kennedy, (206) 615-1283, Roxanne.Kennedy@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Emily Ehlers, (206) 518-4608, Emily.Ehlers@seattle.gov

Seattle Public Utilities Requirements

Jim Mahady, (206) 684-5950, Jim.Mahady@seattle.gov

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

SDCI Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

****The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.****

Existing Public Drainage Infrastructure

Sanitary sewer main location: **11th Ave NW**

Sanitary sewer main size: **8"**

Storm drainage main location: **Holman Rd NW**

Storm drainage main size: **12"**

Drainage

No Available Point of Discharge for Drainage

There is no available off-site point of discharge for drainage from this site. Where it has been determined by the Director that there is no off-site point of discharge (i.e. there is no public storm drainage system within the site frontage or that could be feasibly extended to the site) the project must infiltrate runoff from the area of development on-site.

When infiltrating on-site, infiltration feasibility must first be demonstrated and the Drainage Control Plan must be prepared by a licensed Civil Engineer. In addition to meeting other minimum requirements for the project, the infiltration facility shall be designed to infiltrate the runoff volume from the area of development for the storm event with a 4 percent annual probability (25-year recurrence interval flow) and be sized so that overflows do not exceed 0.0001 cfs during the peak flow with a 4 percent annual probability (25-year recurrence flow). See Seattle Stormwater Manual, Volume 3, Section 4.3.2.1.

Project Type and Drainage Basin

The storm drainage point of discharge (SMC 22.805.020) is located at: **On site (infiltration)** (If feasible. Otherwise a storm main extension will be required.)

Project Type: **Single-family**

Drainage Basin: **NA**

Drainage Control Compliance

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Single-Family projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016, 750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater Management** (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.030.B. and Director's Rule 21-2015.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Wastewater

The wastewater point of discharge (SMC 21.16.070.B) is located at **Public Sanitary Sewer**.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: **Onsite (infiltration)**. (If feasible. Otherwise a storm main extension will be required.)

Side Sewer

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

If there is an increase of dwelling units or buildings the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

Other Requirements

- There is no drainage infrastructure available in the frontage of this project. Also, the project is within the setback above a steep slope that requires a slope stability analysis by a Geotechnical Engineer if on-site infiltration is used. A storm main extension may be required for this project from Holman Road NW.

SDCI Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

11TH AVE NW

New structures must be designed to accommodate right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at <http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found [here](#).

Land Use

An arborist report may be required. See CAM 242 for more detail.

Notes to Applicant

Construction application can not be accepted for review before the associated LBA has been accepted and deemed complete.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the SDCI Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by SDCI within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

Non-ECA

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

Existing ROW Conditions

11TH AVE NW

Street conditions:

Chip seal

Visible pavement width is: 24LF

Curb conditions:

No curb adjacent to site

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place filter fabric, straw bales, straw wattles, or other approved equal to control construction stormwater runoff. Required along the following property lines:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Seattle City Light Requirements

Street/Alley Requirements

11TH AVE NW

Underground electrical facilities/conductors require separation from other utilities. Review City Light Construction Standard 0214.00, Clearances Between SCL Underground Structures and Other Utility Structures in the Public Right-of-Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground electrical lines and facilities along 11th Ave NW.

Relocate existing electric service wire, equipment, and/or meter at project's expense. Relocation is at the applicant's expense.

Other requirements: Please refer to requirements and comments noted in the preliminary assessment report (PAR) under project #3026448.

Easements

SCL power easement may be required. Property survey may be required at project's expense.

Other requirements: At the time of this review, LBA #3026448 has not been approved by City Light and SDCI, or recorded with King County.

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Mario Clack, 206-233-5015, mario.clack@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: To be determined

SDOT Plan Requirements: Plan

SDOT Permit Requirements: Group 2: Over-the-Counter. Obtain from SDOT concurrently with building permit.

Based on the scope of your project and the proximity to the lot line a SIP may be triggered by the extent of construction impacts to existing street, sidewalk or alley improvements. If more than 2,000 sf of impervious surface in the right of way will be replaced a SIP will be required.

Street Improvement Requirements

11TH AVE NW

New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards.

Other requirements: Project might go through SIP process, pending storm drain extension.

Discretionary ROW Improvements

Other recommendations: 11th Ave NW is currently under a pavement moratorium.

SPU Requirements

Water Availability

Your water availability assessment has been approved.
Water Availability Certificate reference number: 20161392
Water Availability Certificate status: Approved with No Changes
Prepared by: Michael Barrett

Existing Water System Information

Proximity of nearest fire hydrant is: 124 feet S of property. Meets standards.
Water Main:
Size: 6 inches Material: Cast Iron Class: 150
- Standard
- Abutting
Water Main is available to serve in: 11th Avenue NW
Distance of main to E margin of street is 20 feet.
Public ROW width is 60 feet.
Water Service(s):
Size: 1.0" Material: Plastic

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:
http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).